



NOTES:

1. DETAIL IS FOR PARKING LOT LIGHT POLES UP TO 20 FEET HIGH.
2. ALL MATERIALS SHALL BE APPROVED BY THE CITY PRIOR TO INSTALLATION.
3. POLES SHALL BE GALVANIZED STEEL, 7-GAUGE, PRIMED AND PAINTED TO COLOR AS APPROVED BY THE CITY.
4. FOUNDATION SHALL HAVE A LIGHT BROOM FINISH AND 1/2" TROWELLED RADIUS EDGE.
5. PROVIDE NO. 3-1/2 CONCRETE PULL BOX WITHIN 5 FEET OF FOUNDATION. PULL BOX COVER SHALL CONTAIN INTEGRAL "STREE LIGHTING" IDENTIFICATION.

REVISION	APPROVED	DATE	CITY OF SANTEE STANDARD DRAWING	APPROVED:
ORIGINAL	C. SCHMITZ	3/20/2018		METAL POLE PARKING LOT LIGHTING STANDARD
			DRAWING NUMBER PW - 19	