

Mayor
John W. Minto
City Council
Ronn Hall
Laura Koval
Rob McNelis
Dustin Trotter

February 12, 2025

To Prospective Bidders:

**CITYWIDE CRACK SEALING PROGRAM 2025
CIP 2025-03**

ADDENDUM NO. 1

This Addendum No. 1 (1 page in total, including this cover page) forms an essential part of the contract documents by revising the following:

1A CONTRACT DOCUMENTS

No changes

1B SPECIFICATIONS

Section 302-15.2

Add the following:

Crack seal shall not be placed within areas on Fanita Drive (Mission Gorge Road to Prospect Avenue) that are currently painted and marked out as locations of asphalt patching as part of the street resurfacing project scheduled in Summer 2025.

There is approximately 16,000 SF currently painted and marked out for asphalt patching on Fanita Drive (Mission Gorge Road to Prospect Avenue) as part of the street resurfacing of Fanita Drive that will not require crack seal material to be placed.

Crack seal material shall be placed gutter to gutter on all streets within the project.

1C DRAWINGS

No changes

1D RFI RESPONSES

No changes



Toby M. Espinola, P.E.
Senior Civil Engineer