



- 1) REFER TO SECTION 15300 OF THE SPECIFICATIONS
- 2) PROTECTION POSTS SHALL BE INSTALLED AS CALLED FOR ON THE PLANS OR AS DIRECTED BY THE DISTRICT ENGINEER PER WM-04
- 3) LOCATE FIRE HYDRANT AS SHOWN ABOVE OR AS DIRECTED BY THE DISTRICT ENGINEER
- 4) FIRE HYDRANTS SHALL BE INSTALLED WITH THE LARGEST PORT PERPENDICULAR TO THE STREET
- 5) AN EASEMENT MAY BE REQUIRED DEPENDING ON LOCATION OF FIRE HYDRANT
- 6) IF THE CONCRETE SLAB IS TO BE INSTALLED ADJACENT TO A CONCRETE CURB OR SIDEWALK A COLD JOINT STRIP SHALL BE INSTALLED
- 7) 1200mm (24") MINIMUM CLEARANCE SHALL BE MAINTAINED ALL AROUND PAD WHEN INSTALLED WITH OR BY A WALL OR OTHER OBSTRUCTIONS

8) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST

LEGEND ON PLANS

FIRE HYDRANT LOCATIONS AND PORT ORIENTATION

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 09/12/2008

DRAWING NUMBER: WF-O4