



NOTES:

1. STANDARD IS FOR WALKWAY LIGHT POLES UP TO 16 FEET HIGH.
2. ALL MATERIALS SHALL BE APPROVED BY THE CITY PRIOR TO INSTALLATION.
3. POLE, POLE BASE, AND FIXTURE, SHALL BE PRIMED AND PAINTED, RAL COLOR NO. 8011.
4. FOUNDATION SHALL HAVE A LIGHT BROOM FINISH WITH 1/2" TROWELLED RADIUS EDGE.
5. PROVIDE NO. 3-1/2 CONCRETE PULL BOX WITHIN 5 FEET OF FOUNDATION. PULL BOX COVER SHALL CONTAIN INTEGRAL "LIGHTING" IDENTIFICATION.

REVISION	APPROVED	DATE	CITY OF SANTEE STANDARD DRAWING	APPROVED:
ORIGINAL	C. SCHMITZ	2/10/2020		METAL POLE WALKWAY LIGHTING STANDARD
			PRINCIPAL CIVIL ENGINEER	
			R.C.E. 60112 DATE: 2/10/2020	
			DRAWING NUMBER PW - 17	